

ow_first

WMPRO >= 1.0 WMMEGA FW >= 2.0

Initiate a OneWire bus scan and return the address of the first device found

Description

mixed ow_first ()

This function starts a new OneWire bus scan and provides the address of the first device found. Currently only DS18B20 temperature sensors are detectable.

Parameters

None

Return Values

An **array** of 8 elements containing the unique OneWire address. Returns **int** 0 if no devices were detected.

Example

```
<?
  $arr=ow_first();
  if ($arr) {
$devname=sprintf("%02X%02X%02X%02X%02X%02X%02X%02X", $arr[0], $arr[1], $arr[2],
  $arr[3], $arr[4], $arr[5], $arr[6], $arr[7]);
    print("Detected the first OneWire device ".$devname);
  } else {
    print("No devices detected.");
  }
?>
```

See Also

[ow_next\(\)](#) - Return the address of the next OneWire device found (after an ow_first)

[ow_read\(\)](#) - Read a byte from the OneWire bus

[ow_read_temp\(\)](#) - Read a temperature from a device on the OneWire bus

[ow_reset\(\)](#) - Reset the OneWire bus

[ow_write\(\)](#) - Write a byte to the OneWire bus

From:

<http://www.wattmon.com/dokuwiki/> - **Wattmon Documentation Wiki**

Permanent link:

http://www.wattmon.com/dokuwiki/uphp/functions/ow_first?rev=1494545426

Last update: **2021/09/13 05:56**

